

1 – AC unit. While Davis was here checking it, a resident reported that the AC unit at the clubhouse was making noise. Davis & I went to check it. I don't know what he heard, but the unit wasn't even on. The t-stat is set for 78, and it was only 73 in the room.

2 – Doug & I checked into prices to get rid of the pile of branches in the boatyard. We will go with Myer's rental for a chipper. We are going to wait for cooler weather because there are a lot of bees in the pile.

3 – Bathhouse #1 (Skipjack) has a small water leak at the hose connection. I tried to tighten it, but it still leaks. I will have Doug look at it on Monday. Maybe it needs a new washer.

4 – Lot # 433 is having an electric issue – the lights flicker sometimes. I checked the outside plug, but it seems to be OK. I'll have the electrician check it on Monday when he is here.

5 – Lot #033 reported that someone used her hose, and left it on the ground. I know that Doug used her hydrant – he planted seed out where the ground was torn up to replace the pipe – but he used our hoses. I'll ask him about it on Monday.

6 – The outlet for the ice machine & soda machine was smoking this morning. I unplugged the ice machine (it's almost empty), and it was OK for a while. Then at about 3PM it started again, so we unplugged the soda machine, and I turned the breaker off. Another job for the electrician on Monday!